

CERTIFICATE

No. B 116111 0004 Rev. 00

Holder of Certificate:

Certification Mark:



Product:

Electric Cables

Electric cables for photovoltaic systems
with a voltage rating of 2,0 kV DC

Model(s):

PV 2000DC (TC5)

1×1.5mm², 1×2.5mm², 1×4mm², 1×6mm²
1×10mm², 1×16mm², 1×25mm², 1×35mm²

PV 2000DC(AL5) & PV2000DC (TCA)

1×4mm², 1×6mm², 1×10mm², 1×16mm²
1×25mm², 1×35mm²

Parameters:

Rated Voltage: DC 2000V

Class (IEC 61140): II

Ambient Temperature: -40°C ~+90°C

Max. Temperature

at conductor: 120°C

Tested according to:

PPP 58209A:2022

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.:

704072303001-00

Valid until:

2028-05-21

Date,

2023-05-22



(Yaqu Alex Liu)